

Proposed Amendments (added text to the code is: <u>underlined</u> , deleted text to the code is: struck through)				
ITEM NUMBER	ARTICLE	SUMMARY	PROPONENT	ACTION
IMC-2018-1	Scope	<p>*Add 'Scope' to read as follows:</p> <p>SCOPE: The provisions of the <i>Georgia State Minimum Standard Mechanical Code</i> shall regulate the design, installation, maintenance, <i>alteration</i> and inspection of mechanical systems that are permanently installed and utilized to provide control of environmental conditions and related processes within buildings. This code shall also regulate those mechanical systems, system components, <i>equipment</i> and appliances specifically addressed herein. The installation of fuel gas distribution piping and <i>equipment</i>, fuel gas-fired appliances and fuel gas-fired <i>appliance</i> venting systems shall be regulated by the Georgia State Minimum Standard <i>Gas Code (International Fuel Gas Code with Georgia Amendments)</i>.</p> <p>Exception: Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories high with separate means of egress and their accessory structures shall comply with the <i>International Residential Code</i>.</p> <p>Motion to approve as Revised by Elaine Powers: 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	R
IMC-2018-2	Scope	<p>The State's minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 25, Chapter 15 and the Rules and Regulations of the Office of Insurance and Safety Fire Commissioner.</p> <p>Motion to approve and carry forward as written by: Chip Greene 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	CF

*Note: These amendments are "proposed only" and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-3	Scope	<p>*Add 'Code Reference Guide' as an Exception to 'Scope' as follows:</p> <p>Exception: The following table titled 'Codes Reference Guide' establishes specific primary and supplementary code applications and is to be applied by the authority having jurisdiction.</p> <table border="1" data-bbox="653 513 1472 1336"> <thead> <tr> <th colspan="3" data-bbox="653 513 1472 597">CODES REFERENCE GUIDE</th> </tr> <tr> <th data-bbox="653 597 1115 651">Area</th> <th data-bbox="1115 597 1272 651">Primary</th> <th data-bbox="1272 597 1472 651">Supplement</th> </tr> </thead> <tbody> <tr> <td data-bbox="653 651 1115 695">Occupancy Classification</td> <td data-bbox="1115 651 1272 695">LSC</td> <td data-bbox="1272 651 1472 695">IBC</td> </tr> <tr> <td data-bbox="653 695 1115 911">Building Construction Types Including allowable height, allowable building areas, and the requirements for sprinkler protection related to minimum building construction types.</td> <td data-bbox="1115 695 1272 911">IBC</td> <td data-bbox="1272 695 1472 911">LSC</td> </tr> <tr> <td data-bbox="653 911 1115 954">Means of Egress</td> <td data-bbox="1115 911 1272 954">LSC</td> <td data-bbox="1272 911 1472 954">NONE</td> </tr> <tr> <td data-bbox="653 954 1115 998">Standpipes</td> <td data-bbox="1115 954 1272 998">IBC</td> <td data-bbox="1272 954 1472 998">IFC</td> </tr> <tr> <td data-bbox="653 998 1115 1042">Interior Finish</td> <td data-bbox="1115 998 1272 1042">LSC</td> <td data-bbox="1272 998 1472 1042">NONE</td> </tr> <tr> <td data-bbox="653 1042 1115 1086">HVAC Systems</td> <td data-bbox="1115 1042 1272 1086">IMC</td> <td data-bbox="1272 1042 1472 1086">NONE</td> </tr> <tr> <td data-bbox="653 1086 1115 1130">Vertical Openings</td> <td data-bbox="1115 1086 1272 1130">LSC</td> <td data-bbox="1272 1086 1472 1130">NONE</td> </tr> <tr> <td data-bbox="653 1130 1115 1190">Sprinkler Systems minimum construction standard</td> <td data-bbox="1115 1130 1272 1190">LSC</td> <td data-bbox="1272 1130 1472 1190">NONE</td> </tr> <tr> <td data-bbox="653 1190 1115 1234">Fire Alarm Systems</td> <td data-bbox="1115 1190 1272 1234">LSC</td> <td data-bbox="1272 1190 1472 1234">NONE</td> </tr> <tr> <td data-bbox="653 1234 1115 1336">Smoke Alarms and Smoke Detection Systems</td> <td data-bbox="1115 1234 1272 1336">State Statute and LSC</td> <td data-bbox="1272 1234 1472 1336">NONE</td> </tr> </tbody> </table>	CODES REFERENCE GUIDE			Area	Primary	Supplement	Occupancy Classification	LSC	IBC	Building Construction Types Including allowable height, allowable building areas, and the requirements for sprinkler protection related to minimum building construction types.	IBC	LSC	Means of Egress	LSC	NONE	Standpipes	IBC	IFC	Interior Finish	LSC	NONE	HVAC Systems	IMC	NONE	Vertical Openings	LSC	NONE	Sprinkler Systems minimum construction standard	LSC	NONE	Fire Alarm Systems	LSC	NONE	Smoke Alarms and Smoke Detection Systems	State Statute and LSC	NONE	Task Force	CF
CODES REFERENCE GUIDE																																								
Area	Primary	Supplement																																						
Occupancy Classification	LSC	IBC																																						
Building Construction Types Including allowable height, allowable building areas, and the requirements for sprinkler protection related to minimum building construction types.	IBC	LSC																																						
Means of Egress	LSC	NONE																																						
Standpipes	IBC	IFC																																						
Interior Finish	LSC	NONE																																						
HVAC Systems	IMC	NONE																																						
Vertical Openings	LSC	NONE																																						
Sprinkler Systems minimum construction standard	LSC	NONE																																						
Fire Alarm Systems	LSC	NONE																																						
Smoke Alarms and Smoke Detection Systems	State Statute and LSC	NONE																																						

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

		<table border="1"> <tr> <td>Portable Fire Extinguishers</td> <td>IFC</td> <td>NONE</td> </tr> <tr> <td>Cooking Equipment</td> <td>LSC and NFPA 96</td> <td>NONE</td> </tr> <tr> <td>Fuel Fired Appliances</td> <td>IFGC</td> <td>NFPA 54</td> </tr> <tr> <td>Liquid Petroleum Gas</td> <td>NFPA 58</td> <td>NFPA 54</td> </tr> <tr> <td>Compressed Natural Gas</td> <td>NFPA 52</td> <td>NONE</td> </tr> </table> <p>Motion to approve and carry forward as written by: Chip Greene 2nd by: Stan Everett Passed: Unanimous</p>	Portable Fire Extinguishers	IFC	NONE	Cooking Equipment	LSC and NFPA 96	NONE	Fuel Fired Appliances	IFGC	NFPA 54	Liquid Petroleum Gas	NFPA 58	NFPA 54	Compressed Natural Gas	NFPA 52	NONE		
Portable Fire Extinguishers	IFC	NONE																	
Cooking Equipment	LSC and NFPA 96	NONE																	
Fuel Fired Appliances	IFGC	NFPA 54																	
Liquid Petroleum Gas	NFPA 58	NFPA 54																	
Compressed Natural Gas	NFPA 52	NONE																	
IMC-2018-4	Chapter 1	<p>*Delete Chapter 1 ‘Administration’ without substitution. Chapter 1 to remain in the Code as a <i>reference and</i> guide for local governments in the development of their own <i>Administrative Procedures</i>.</p> <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	CF															
IMC-2018-5	202	<p>*Add new definition for ‘Cooling Tower’ to read as follows:</p> <p>COOLING TOWER. A building heat removal device used to transfer process waste heat to the atmosphere.</p> <p>Motion to disapprove and not carry forward by: Michael Knox 2nd by: Chip Green Passed: Unanimous</p>	Task Force	D															

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-6	202	<p>*Add Definition of ‘MAKE-UP AIR’ to read as follows:</p> <p>MAKE-UP AIR. SEE ENVIRONMENTAL AIR Motion to approve and carry forward as written by: Michael Knox 2nd by: Chip Green Passed: Unanimous</p>	Task Force	CF
IMC-2018-8	301.1	<p>*Revise Section 301.1 ‘Scope’ to read as follows:</p> <p>301.1 Scope. This chapter shall govern the approval and installation of all equipment and appliances that comprise parts of the building mechanical systems regulated by this code. Motion to approve and carry forward as written by: Michael Knox 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	CF
IMC-2018-9	301.2	<p>*Revise Section 301.2 ‘Energy utilization’ read as follows:</p> <p>301.2 Energy utilization. Heating, ventilating and air-conditioning systems of all structures shall be designed and installed for efficient utilization of energy in accordance with the <i>International Energy Conservation Code</i>. Cooling towers installed in new construction shall be in compliance with ASHRAE, Standard 90.1. Motion to approve and carry forward as written by: Michael Brown 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	CF

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-10	301.3	<p>* Revise Section 301.3 ‘Identification’ to read as follows:</p> <p>301.3 Identification. Each length of pipe and tubing utilized in a mechanical system shall bear the identification of the manufacturer. If not provided on the packaging or crating or by other approved documentation, each pipe fitting, utilized in a mechanical system, shall bear the identification of the manufacturer.</p> <p>Motion to disapprove and NOT carry forward as written by: Stan Everett 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	D
IMC-2018-11	301.4	<p>*Revise Section 301.4 ‘Plastic pipe, fittings and components’ to read as follows:</p> <p>301.4 Plastic pipe, fittings and components. Plastic pipe, fittings and components shall conform to NSF 14.</p> <p>Motion to disapprove and NOT carry forward as written by: Stan Everett 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	D
IMC-2018-13	301.5	<p>*Delete Section 301.5 ‘Third-party testing and certification’ and substitute to read as follows:</p> <p>301.5 Application. All piping, tubing and fittings shall comply with the applicable referenced standards, specifications and performance criteria of this code and shall be identified in accordance with Section 301.3</p> <p>Motion to disapprove and NOT carry forward as written by: Mark Rice 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	D

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-14	301.7	<p>*Revise Section 301.7 ‘ Listed and labeled’ to read as follows:</p> <p>301.7 Listed and labeled. Appliances regulated by this code shall be <i>listed</i> and <i>labeled</i> for the application in which they are installed and used, unless otherwise approved.</p> <p>Exception to Remain Motion to approve as revised by: Mark Rice 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	R
IMC-2018-15	301.19	<p>*Add new Section 301.19 ‘Related Fire Codes’ to read as follows:</p> <p>301.19 Related fire codes. Any reference to the <i>International Fire Code</i> and/or NFPA standards in any chapter of this code shall be to the latest edition as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p> <p>Motion to approve and carry forward as written by: Chip Greene 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	CF
IMC-2018-17	312.1	<p>*Revise Section 312.1 ‘Load calculations’ to add exception as follows:</p> <p>312.1 Load calculations.</p> <p>Exception: For R-2 occupancies of three stories or less in height, heating and cooling equipment may be sized based on building loads calculated in accordance with ACCA Manual J.</p> <p>Motion to disapprove and NOT carry forward as written by: Mark Rice 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	D

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-18	401.2	<p>*Revise Section 401.2 ‘Ventilation required’ to add at the end of first paragraph as follows: ...with Section 403. A private dwelling unit shall be ventilated by mechanical means in accordance with Section M1507.3 of the IRC or ASHRAE 62.2, and may not be used interchangeably. Motion to disapprove and not carry forward by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	D
IMC-2018-19	401.7	<p>*Add Section 401.7 ‘Alternate ventilation procedures’ to read as follows: 401.7 Alternative ventilation procedures. As an alternative to Chapter 4, the following shall be permitted:</p> <ol style="list-style-type: none"> 1. Ventilation Rate Procedure, Natural Ventilation Procedure or Indoor Air Quality Procedure, as prescribed by ASHRAE 62.1. Software programs to calculate outdoor ventilation air may be used to demonstrate ASHRAE 62.1 compliance, as approved by authority having jurisdiction. 2. Ventilation in Healthcare Facilities shall comply with ANSI/ASHRAE/ASHE Standard 170. 3. 2. ...or a combination of ASHRAE 62.1 and ANSI/ASHRAE/ASHE Standard 170 may be utilized for different occupancy types within a single building. <p>Motion to approve and carry forward as revised by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	R

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-20	406.1	<p>*Revise Section 406.1 ‘General’ to add exception as follows:</p> <p>406.1 General. Exception: Unvented attic assemblies that comply with Section R806.5 of the International Residential Code. Motion to disapprove and not carry forward by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	D
IMC-2018-21	501.3	<p>* Revise Exception #1 to read as follows:</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Whole-house ventilation-type attic fans shall be permitted to discharge into the ventilated attic space of <i>dwelling units</i> having private attics, provided the installed system meets paragraph 501.4 requirements for pressure equalization. <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Michael Brown Passed: Unanimous</p>	Task Force	CF
IMC-2018-22	505.7	<p>*Add new Section 505.7 ‘Commercial installations of domestic systems’ to read as follows:</p> <p>505.7 Commercial installations of domestic systems. Commercial installations of domestic systems shall comply with the current Life Safety Code NFPA 101 and 96 standards as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Motion to approve as revised by: Jeff Yoder 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	R

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-23		<p>*Add new Section 505.4 ‘Exhaust ducts’ to read as follows: 505.4 Exhaust ducts. Exhaust ducts for domestic range hoods, installed in commercial applications shall be vented to the outside and shall be constructed of Type B vent or smooth- wall duct constructed of 0.0157 inch (0.4mm) galvanized steel. Motion to disapprove and not carry forward by: Michael Knox 2nd by: Michael O’Brien Passed: Unanimous</p>	Task Force	D
IMC-2018-24	506.1	<p>*Delete Section 506.1 ‘General’ and substitute the following to read: 506.1 General. The State’s minimum requirements for Type I commercial kitchen hood ventilation system ducts and exhaust equipment shall be designed, constructed and installed in accordance with the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Other commercial kitchen hood ventilation system ducts and exhaust equipment shall comply with the requirements of this section. Motion to approve and carry forward as revised by: Michael O’Brien 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	R
IMC-2018-25	507.1	<p>*Delete Section 507.1 ‘General’ and substitute the following: 507.1 General. The State’s minimum requirements for Type I commercial kitchen hoods shall be designed, constructed and installed in accordance with the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Other commercial kitchen hoods shall comply with the requirements of this section. Motion to approve and carry forward as revised by: Michael O’Brien 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	R

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-27	507.1.3	<p>*Delete Section 507.1.3 ‘Domestic cooking appliances used for commercial purposes’ without substitution.</p> <p>Motion to approve and carry forward as written by: Michael O’Brien 2nd by: Chip Greene Passed: Unanimous</p>	Task Force	CF
IMC-2018-28	508.1	<p>*Renumber Section 508.1 ‘Makeup air’ as 508.2, renumber Section 508.2 ‘Compensating Hoods’ as 508.3, and add new section 508.1 ‘General’ as follows:</p> <p>508.1 General. The State’s minimum requirements for commercial kitchen makeup air Type I hoods shall be in accordance with the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Commercial kitchen makeup air for Type II hoods shall comply with the requirements of this section.</p> <p>Motion to approve and carry forward as revised by: Mark Rice 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	R
IMC-2018-29	509.1	<p>*Delete Section 509.1 ‘Where required’ and substitute the following to read:</p> <p>509.1 Where required. The State’s minimum requirements for fire suppression systems for commercial cooking equipment shall be established by the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p> <p>Motion to approve and carry forward as written by: Chip Green 2nd by: Jeff Yoder Passed: Unanimous</p>	Task Force	R

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-30	603.2	<p>*Revise the first sentence Section 603.2 ‘Duct sizing’ to read as follows:</p> <p>603.2 Duct sizing. Ducts installed within a one-or two-family dwelling unit shall be designed and sized in accordance with ACCA Manual D or other approved methods. (Remainder of section left unchanged).</p> <p>Motion to disapprove and not carry forward by: Stan Everett 2nd by: Michael Brown Passed: Unanimous</p>	Task Force	D
IMC-2018-31	606.2.1	<p>*Revise Section 606.2.1 ‘Return air systems’ as follows:</p> <p>606.2.1 Supply air systems. Smoke detectors shall be installed in supply air systems with a design capacity greater than 2,000 cfm, in the supply air duct downstream of any filters, fan motors, outdoor air connections, and upstream of any branch connections or decontamination equipment and appliances.</p> <p>Exception: Smoke detectors are not required in the supply air system where all portions of the building served by the air distribution system are protected by area smoke detectors connected to a fire alarm system in accordance with NFPA 72. The area smoke detection system shall comply with Section 606.4.</p> <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Michael Brown Passed: Unanimous</p>	Task Force	CF

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-32	606.2.2	<p>*Revise Section 606.2.2 ‘Common supply and return air systems’ as follows:</p> <p>606.2.2 Common supply and return air systems. Where multiple air-handling systems share common supply or return air ducts or plenums with a combined design capacity greater than 2,000 cfm, the supply air system shall be provided with smoke detectors in accordance with Section 606.2.1.</p> <p>Exception: Individual smoke detectors shall not be required for each fan-powered unit, provide that such units do not have and individual design capacity greater than 2,000 cfm and will be shut down by activation of one of the following;</p> <ol style="list-style-type: none"> 1. Smoke detectors required by Sections 606.2.1 and 606.2.3. 2. An approved area smoke detector system located in the supply air duct serving such units. 3. An area smoke detectors system as prescribed in the exception to Section 606.2.1. <p>In all cases, the smoke detectors shall comply with sections 606.4 and 606.4.1.</p> <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Michael O’Brien Passed: Unanimous</p>	Task Force	CF
-------------	---------	---	------------	----

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-33	606.4.1	<p>*Revise Section 606.4.1 ‘Supervision’ to read as follows:</p> <p>606.4.1 Supervision. The duct smoke detectors shall be connected to a fire alarm system where a fire alarm system is required by the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. The actuation of a duct smoke detector shall activate a visual and audible supervisory signal at a constantly attended location.</p> <p>Motion to approve and carry forward as revised by: Jeff Yoder 2nd by: Stan Everett Passed: 7 to 1 in favor with Michael Knox opposed.</p>	Task Force	R
IMC-2018-34	804.3.8	<p>*Delete requirement Revise #2 and #3 of Section 804.3.8 ‘Mechanical draft systems for manually fired appliances and fireplaces’ and revise to read as follows:</p> <p>804.3.8 Mechanical draft systems for manually fired appliances and fireplaces. Requirement</p> <p>#2 A device shall be installed that produces visible and audible warning upon failure of the mechanical draft device or loss of electrical power, at any time that the mechanical draft device is turned on. <u>This device shall be installed in an approved location, receive power from the building wiring and equipped with a battery backup.</u></p> <p>#3 A smoke detector shall be installed in the room with the <i>appliance</i> or fireplace. <u>This device shall receive power from the building wiring and equipped with a battery backup.</u></p> <p>Motion to approve and carry forward as revised by: Michael Brown 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	R

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-35	908.1	<p>* Revise Section 908.1 ‘General’ to read as follows:</p> <p>908.1 General. A cooling tower used in conjunction with an air-conditioning appliance shall be installed in accordance with the manufacturer’s installation instructions. Factory-built cooling towers shall be listed in accordance with UL 1995. The standards related to high efficiency cooling towers shall include without limitation the minimum standards prescribed by the ASHRAE, Standard 90.1.</p> <p>Motion to approve and carry forward as written by: Chip Greene 2nd by: Michael Brown Passed: Unanimous</p>	Task Force	CF
IMC-2018-36	917.1	<p>*Add Exception to 917.1 ‘Prohibited location’ to read as follows.</p> <p>Exception: <i>Listed and Labeled</i> commercial cooking appliances may be installed in <i>dwelling units</i> and domestic kitchens when such installation is designed by a Georgia Licensed Professional Engineer and accepted by the local authority having jurisdiction.</p> <p>Motion to approve and carry forward as revised by: Stan Everett 2nd by: Michael O’Brien Passed: Unanimous</p>	Task Force	R
IMC-2018-37	917.2	<p>*Delete Section 917.2 ‘Domestic appliances’ without substitution.</p> <p>Motion to approve and carry forward by: Stan Everett 2nd by: Michael O’Brien Passed: Unanimous</p> <p>Note: Section was Reinstated as written in 2015 via amendment put forward by Greg Johnson but the 2018 IMC Task Force voted to move forward with the deletion of section 917.2</p>	Task Force	CF

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-38	1001.1	<p>*Revise Section 1001.1 ‘Scope’ to add at the end of first paragraph as follows:</p> <p>1001.1 Scope. ...and pressure vessels. The State’s minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 25, Chapter 15 and the as adopted and amended Rules and Regulations of the Office of Insurance and Safety Fire Commissioner.</p> <p>Motion to approve as revised by: Chip Greene 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	R
IMC-2018-39	1007.1	<p>*Revise Section 1007.1 ‘General’ to add at the end as follows:</p> <p>1007.1 General. ...low-water cutoff control. In lieu of the low-water cutoff control, a flow switch or other mechanism as recommended by the manufacturer shall be allowed for water tube boilers.</p> <p>Motion to disapprove and not carry forward by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	D
IMC-2018-40	1105.3	<p>*Re-number Section [F] 1105.3 ‘Refrigerant detector’ as 1105.3 and revise to read as follows:</p> <p>1105.3 Refrigerant detector. Refrigerant detectors in machinery rooms shall be provided as required in accordance with ASHRAE 15.</p> <p>Motion to approve and carry forward as written by: Mark Rice 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	CF

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-41	1106.6	<p>*Renumber Section [F] 1106.6 ‘Remote Controls’ as 1106.6 and revise to read as follows:</p> <p>1106.6 Remote controls. Remote control of the mechanical equipment and appliances located in the machinery room shall be provided as required by “ASHRAE Standard 15”.</p> <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Chip Greene Passed: Unanimous</p>	Task Force	CF
IMC-2018-42	1106.7	<p>*Renumber Section [F] 1106.7 ‘Emergency signs and labels’ as 1106.7 and revise to read as follows:</p> <p>1106.7 Emergency signs and labels. Refrigeration units and systems shall be provided with <i>approved</i> emergency signs, charts, and labels in accordance with ASHRAE 15.</p> <p>Motion to approve and carry forward as written by: Mark Rice 2nd by: Stan Everett Passed: Unanimous</p>	Task Force	CF
IMC-2018-43	1206.8	<p>*Revise Section 1206.8 ‘Steam piping pitch’ to add at the end as follows:</p> <p>1206.8 Steam piping pitch. ...the steam piping. Branch piping from steam mains shall be taken off at the top of the pipe.</p> <p>Motion to approve and carry forward as written by: Chip Greene 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	CF

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-44	1301.1	<p>*Revise Section 1301.1 ‘Scope’ to add at the end as follows:</p> <p>1301.1 Scope. ...International Fire Code. The State’s minimum requirements for fuel oil piping and storage shall be as established by the Georgia State Minimum Fire Safety Standards and the as adopted and amended Rules and Regulations of the Georgia Insurance and Safety Fire Commissioner. Any areas not addressed by the Georgia State Minimum Fire Safety Standards shall be regulated by this chapter.</p> <p>Motion to approve as revised by: Stan Everett 2nd by: Michael Knox Passed: Unanimous</p>	Task Force	R
IMC-2018-45	1403.2.1	<p>*Add new Section 1403.2.1 ‘Protection of drains’ to read as follows:</p> <p>1403.2.1 Protection of drains. Drains serving heat transfer fluids over 140°F (60°C) or which are toxic or corrosive shall be protected in accordance with the requirements of <i>the International Plumbing Code</i>.</p> <p>Motion to approve and carry forward as written by: Stan Everett 2nd by: Michael Brown Passed: Unanimous</p>	Task Force	CF
IMC-2018-46	1402.9	<p>*Add new Section 1402.9 ‘Warning label’ to read as follows:</p> <p>1402.9 Warning label. Drains in solar systems where high temperature, high pressure, or hazardous fluids are discharged shall have a warning label. For hazardous fluids, the label shall describe the hazardous properties of the fluid and emergency first aid procedures. Valves regulating such a discharge shall not be readily accessible to unauthorized personnel.</p> <p>Motion to disapprove and NOT carry forward by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>	Task Force	D

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-47		<p>*Revise Chapter 15 ‘Referenced Standards’ to add as follows:</p> <p>ACCA Air Conditioning Contractors of America 2800 Shirlington Road, Suite 300 Arlington, VA 22206</p> <table border="1"> <thead> <tr> <th>Standard reference number</th> <th>Title</th> <th>Referenced in code section number</th> </tr> </thead> <tbody> <tr> <td>Manual J 86 or 02</td> <td>Residential Load Calculations 7th or 8th Edition</td> <td>312.1, GA Amendments</td> </tr> <tr> <td>Manual D 2009</td> <td>Residential Duct Systems</td> <td>603.2, GA Amendments</td> </tr> </tbody> </table> <p>American Society of Heating, Refrigeration and Air Conditioning Engineers, Inc. 1791 Tullie Circle, NE</p> <p>ASHRAE Atlanta, GA 30329-2305</p> <table border="1"> <thead> <tr> <th>Standard reference number</th> <th>Title</th> <th>Referenced in code section number</th> </tr> </thead> <tbody> <tr> <td>90.1--2016</td> <td>Energy Standard for Buildings Except Low-Rise Residential Buildings</td> <td>301.2, 908.1 GA Amendments</td> </tr> <tr> <td>62.1--2016</td> <td>Ventilation for Acceptable Indoor Air Quality</td> <td>401.7 GA Amendments</td> </tr> </tbody> </table>	Standard reference number	Title	Referenced in code section number	Manual J 86 or 02	Residential Load Calculations 7 th or 8 th Edition	312.1, GA Amendments	Manual D 2009	Residential Duct Systems	603.2, GA Amendments	Standard reference number	Title	Referenced in code section number	90.1--2016	Energy Standard for Buildings Except Low-Rise Residential Buildings	301.2, 908.1 GA Amendments	62.1--2016	Ventilation for Acceptable Indoor Air Quality	401.7 GA Amendments	Task Force	R
Standard reference number	Title	Referenced in code section number																				
Manual J 86 or 02	Residential Load Calculations 7 th or 8 th Edition	312.1, GA Amendments																				
Manual D 2009	Residential Duct Systems	603.2, GA Amendments																				
Standard reference number	Title	Referenced in code section number																				
90.1--2016	Energy Standard for Buildings Except Low-Rise Residential Buildings	301.2, 908.1 GA Amendments																				
62.1--2016	Ventilation for Acceptable Indoor Air Quality	401.7 GA Amendments																				

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		15--2016	Safety Standard for Refrigeration Systems	1105.3, 1106.6, 1106.7, GA Amendments		
		170-2017	Ventilation of Health Care Facilities	401.7, GA Amendments		
		62.2-2010	Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings	401.2, GA Amendments		
<hr/> National Fire Protection Association Battery march Park NFPA Quincy, MA 02269						
		<u>Standard reference number</u>	<u>Title</u>	<u>Referenced in code section number</u>		
		96	Standard for Ventilation and Fire Protection of Commercial Cooking Operations	505.7,506.1, 507.1, 508. 509.1, GA Amendments		
		101	Life Safety Code	506.1, 507.1, 508.1, 509.1 GA Amendments		
<hr/> <p>Motion to approve as revised by: Stan Everett 2nd by: Mark Rice Passed: Unanimous</p>						

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

<p>IMC-2018-48</p>	<p>908.8.2</p>	<p>*Revise Section 908.8.2 ‘Drift Eliminators’ and add new section 908.8.3 ‘Secondary Disinfection’ to read as follows:</p> <p>908.8.2 Drift Eliminators Cooling towers and evaporative condensers shall be equipped with drift eliminators that have a maximum drift rate of 005 .001 percent of the circulated water flow rate as established in the equipment’s design.</p> <p>908.8.3 Secondary Disinfection Where required by the code inspector, a secondary disinfection which has been proven to kill legionella bacteria at a minimum rate of 99% in a circulating loop shall be used in addition to the cooling tower’s chemical treatment regimen. Approved technologies shall be 3rd party certified in a lab or field to prove its efficacy and use for cooling tower applications in killing legionella bacteria.</p> <p>Died for no action</p>	<p>Travis Glover-Southeast Pump & Equipment, Inc.</p>	<p>D</p>
<p>IMC-2018-49</p>	<p>1402.4</p>	<p>*Revise Section 1402.4 ‘Protection from freezing’ to read as follows:</p> <p>1402.4 Protection from freezing ...at the lowest ambient temperatures that will be encountered. Freeze... Remainder of paragraph to remain unchanged</p> <p>Motion to add new amendment: Michael Knox 2nd: Stan Everett Passed: Unanimous</p>	<p>Task Force</p>	<p>A</p>

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

<p>IMC-2018-50</p>	<p>505.3.1</p>	<p>*Add new section 505.4 ‘Exhaust Ducts for domestic range hoods installed in commercial applications’ to read as follows</p> <p>505.3.1 Exhaust Ducts for domestic range hoods installed in commercial applications Exhaust ducts for domestic range hoods installed in commercial applications shall be vented to the outside and shall be constructed of (a) Type B vent, or (b) smooth wall duct constructed of galvanized or stainless steel with a minimum duct thickness of 0.0157” (0.40 mm) or constructed of aluminum or copper with a minimum duct thickness of 0.023” (0.58mm).</p> <p>Motion to add new amendment: Michael O’Brien 2nd: Stan Everett Passed: Unanimous</p>	<p>Task Force</p>	<p>A</p>
<p>IMC-2018-51</p>	<p>306.3</p>	<p>*Add new exception 3 in section 306.3 to read as follows</p> <p>Exceptions: 3. In Residential Occupancies attics containing appliances or mechanical equipment service shall be accessible by pull down stairs or other permanent steps and at a minimum be sized to allow the removal of the largest appliance.</p> <p>Motion to add new amendment: Elaine Powers 2nd: Michael Knox Passed: Unanimous</p>	<p>Task Force</p>	<p>A</p>

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)