

CITY OF MOUNTAIN PARK



*Mountain Park Georgia
Incorporated 1927
118 Lakeshore Drive
Mountain Park, Georgia 30075*

ATLANTA METRO 301

29 SEP 2023 PM 13 L

Department of Community Affairs
ATTN: Director, Office of Construction
Codes and Research
60 Executive Park South, NE
Atlanta, GA 30329

30329-225799



R 162 - 53

RESOLUTION
FINDINGS ON PROPOSED LOCAL AMENDMENT TO PLUMBING CODE FOR WATER EFFICIENCY
SUBMISSION OF PROPOSED AMENDMENT TO DCA

WHEREAS, the current minimum water efficiency requirements for buildings in the City of Mountain Park, Georgia's jurisdiction is the Georgia State Minimum Standard Plumbing Code ("Georgia Plumbing Code") as approved and adopted by the Georgia Department of Community Affairs ("DCA") from time to time;

WHEREAS, the City, like all local governments in the State of Georgia, is authorized under O.C.G.A. § 8-2-25(c) to adopt local requirements when needed that are more stringent than the Georgia Plumbing Code based on local climatic, geologic, topographic, or public safety factors;

WHEREAS, the long-term availability, reliability, and resiliency of water supplies is a critical need of the City and water efficiency is essential to meeting this need;

WHEREAS, the "Local Amendments to Plumbing Code" shown in the redline in Attachment A are more stringent than the Georgia Plumbing Code on water efficacy because the amendments require even more efficient uses of water and provide clarifications on existing allowable practices;

WHEREAS, based on its local climatic, geologic, topographic factors included in the regional water resources plan prepared by the Metropolitan North Georgia Water Planning District ("Metro Water District"), of which the City is a part, water conservation is especially important to the City and the Metro Water District;

WHEREAS, the City has become aware that more water efficient technologies have become widely available at comparable prices and performance to the water efficient technologies currently required as the minimum in the Georgia Plumbing Code;

NOW, THEREFORE, BE IT RESOLVED THAT:

1. The governing body of the City finds that, based on local climatic, geographic, topographic, and public safety factors included in the Metro Water District's plans, it is justified in adopting local water efficiency requirements more stringent than the Georgia Plumbing Code;

2. The mayor and City Council is considering codifying these water efficiency requirements in local code as an amendment to Georgia Plumbing Code in the form of the Local Amendments to Plumbing Code shown in the redline in Attachment A; and

3. The City is directing its staff to submit this resolution and the Local Amendments to Plumbing Code to DCA for review and comment within 60 days as required by O.C.G.A. § 8-2-25(c)(1).

So resolved 25 day of September, 2023.

Attest:


Jennifer Zalokar, City Clerk


Jim Still, Mayor

minute at 860 pounds per square inch of pressure, ~~and is listed in the WaterSense Specification for Showerheads, and meets the US Department Definition of Energy definition of showerhead.~~

Chapter 6, Section 604.4 Maximum Flow and Water Consumption. Revise Section 604.4 to read as follows:

Consistent with the general approach taken in Georgia, these Maximum Flow and Water Consumption requirements and related definitions in Section 604.4 of the plumbing code shall apply to all plumbing systems, including those in one- and two-family dwellings. The maximum water consumption flow rates and quantities for all plumbing fixtures and fixture fittings shall be in accordance with Table 604.4.

Exceptions:

1. Blowout design water closets having a water consumption not greater than 3¹/₂ gallons (13 L) per flushing cycle.
2. Vegetable sprays.
3. Clinical sinks having a water consumption not greater than 4¹/₂ gallons (17 L) per flushing cycle.
4. Laundry tray sinks and service sinks.
5. Emergency showers and eye wash stations.

TABLE 604.4
MAXIMUM FLOW RATES AND CONSUMPTION FOR
PLUMBING FIXTURES AND FIXTURE FITTINGS

PLUMBING FIXTURE OR FIXTURE FITTING	MAXIMUM FLOW RATE OR QUANTITY ^b
<u>Lavatory faucet and replacement aerators, private</u>	<u>WaterSense Labeled & 1.25 gpm at 60 psi^f</u>
Lavatory faucet, public (metering)	0.25 gallon per metering cycle
Lavatory, public (other than metering)	0.5 gpm at 60 psi
Showerhead ^a	<u>WaterSense Labeled & 2.52.0 gpm at 8060 psi^f</u>
<u>Kitchen Sink faucet and replacement aerators</u>	2.01.8 gpm at 60 psi ^{f, B}
Urinal	0.5 gallon per flushing cycle ^f
Water closet	1.28 gallons per flushing cycle ^{c, d, e, f}

For SI: 1 gallon = 3.785 L, 1 gallon per minute = 3.785 L/m,
1 pound per square inch = 6.895 kPa.

a. A hand-held shower spray is a shower head. As point of clarification, multiple shower heads may be installed in a single shower enclosure so long as each shower head individually meets the maximum flow rate, the

3. Areas less than ten (10) feet in width in any direction shall be irrigated with subsurface irrigation or by other means that produces no overspray or runoff.

4. Narrow or irregular shaped landscaped areas, less than four (4) feet in any direction across opposing boundaries shall not be irrigated by any irrigation emission device except sub-surface or low flow emitters with flow rates not to exceed 6.3 gallons per hour.

604.4.3.2 Landscape Irrigation System Required Components. All new landscape irrigation systems shall include the following components:

1. A rain sensor shut-off installed in an area that is unobstructed by trees, roof over hangs, or anything else that might block rain from triggering the rain sensor shutoff.

2. A master shut-off valve for each controller installed as close as possible to the point of connection of the water but downstream of the backflow prevention assembly.

3. Pressure-regulating devices such as valve pressure regulators, sprinkler head pressure regulators, inline pressure regulators, WaterSense spray sprinkler bodies, or other devices shall be installed as needed to achieve the manufacturer's recommended pressure range at the emission devices for optimal performance.

4. Except for landscape irrigation systems serving a single-family home, all other systems must also include:

(a) a WaterSense irrigation controller; and

(b) at least one flow sensor, which must be installed at or near the supply point of the landscape irrigation system and shall interface with the control system, that when connected to the WaterSense controller will detect and report high flow conditions to such controller and automatically shut master valves. The flow sensor serves to aid in detecting leaks or abnormal flow conditions by suspending irrigation. High flow conditions should be consistent with manufacturers' recommendations and specifications.

Chapter 13 NONPOTABLE WATER SYSTEMS, Section 1304 Reclaimed Water Systems. Revise Section 1304.3.2 to read as follows:

1304.3.2 Connections to water supply. Reclaimed water provided from a reclaimed wastewater treatment system facility permitted by the Environmental Protection Division may be used to supply water closets, urinals, trap primers for floor drains and floor sinks, water features and other uses approved by the Authority Having Jurisdiction, in motels, hotels, apartment and condominium buildings, and commercial, industrial, and institutional buildings, where the individual guest or occupant does not have access to plumbing. Also, other systems that may use a lesser quality of water than potable water such as water chillers, carwashes or an industrial process may be supplied with reclaimed water provided from a reclaimed wastewater treatment facility permitted by the Environmental Protection Division. The use of reclaimed water sourced from any new private reclaimed wastewater treatment system for outdoor irrigation shall be limited to golf courses and agriculture operations as defined in the Official Code of Georgia Section 1-3-3, and such reclaimed water shall not be approved for use for irrigating any other outdoor landscape such as ground cover, tree, shrubs, or other plants. These limitations do not apply to reclaimed water sourced from existing private reclaimed water systems or from existing or new, governmentally-owned reclaimed wastewater treatment systems.

Appendix E, Section E101.1.2. Revise Section E.101.1.2 to read as follows:

Because of the variable conditions encountered in hydraulic design, it is impractical to specify definite and detailed rules for sizing of the water piping system. Accordingly, other sizing or design methods conforming to good engineering practice standards are acceptable alternatives to those presented herein. Without limiting the foregoing, such acceptable design methods may include for multi-family buildings the Peak Water Demand